

APPLICATION No.: 12989

TAP CLEARED

83-29-1654

LOCATION: 15 Tremont S.W. Cor. Maple View Terrace

OWNER:

MEASURES:

5/8"

W from

Tremont

26.4 ft.

N from S line

Maple View Terrace

4.4 ft.

W from E line

House

6.2 ft.

March 4, 1982 Retapped new 6" main. Renewed from the
main to a point 1 ft. from the main.

3/4" Corporation 1 ft. - 3/4" Copper tubing

1 - 5/8" x 3/4" lead to copper adapt. XXS

- - -

July 28, 1983 Renewed from main to cellar.

30'-3/4" copper (17' ins.) 3/4" curb stop

Reused couplin at corp. tap. 1-Stop box

- - -

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]