

APPLICATION No.: 13122

## TAP CLEARED

LOCATION: ✓ 66 Independent St.OWNER: Mariano R. Tore

MEASURES: 5/8" H lead Feb. 2, 1910  
E from Crapo St. 185.5 ft.  
N from S line Independent St. 8.2 ft.  
E from W line house 11.3 ft.

1-30-02 Renewed from main to property line. Stock:  
18 ft. - 3/4" Copper tubing, 1-3/4" Curb stop, 1-Caldwell  
Stop Box, 1-5/8"x3/4" lead to cop. adapt. XXS,  
1- 5/8"x3/4" Fig. 413.

1" Copper Service

05/29/2019 Lead Service Line Replacement Program  
Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (ft) 18.5

Distance from curb face to curb stop (ft) 1

Depth of service (ft) 4

Total length of new service installed (Ft) 18.5

Curb stop replaced: NO, Corporation replaced: NO

Ball valve furnished: Yes size 1"

DATE

BEF.

AFT.

REMARKS

1/29/02

830

AM

2002-050-1546

1-30-02 Tap reamed

[illegible]

# CHARGE OUTS

