

APPLICATION No.: 13167

TAP CLEARED

LOCATION: 15 Maple View Terrace

DATE

BEF.

AFT.

REMARKS

OWNER: Leon M. Huggins

MEASURES: 5/8"

W from

Tremont

122.2 ft.

S from N line

Maple View Terrace

4.4 ft.

W from E line

H House

2.0 ft.

March 8, 1982 Retapped new 6" main. Renewed from the
main to a point 3 ft. from the main.

3 ft. - 3/4" Copper tubing 3/4" Corporation

1 - 5/8" x 3/4" lead to cop adapt. XXS

7/31/92: Pavao Const. renewed from main to prop line

Pavao pulled corp tap from main All stock & labor by Pavao Const.

23.5 ft 3/4" copper tubing 1-3/4" curb stop 1-Caldwell stop box

1-3/4x5/8 lead-cop adapt.xxs 1-3/.4" corp tap. Chap 90 proj

Insp.J.Rodrigues t-Souza=====

02.27.2024 - DPI replaced lead line Curb Stop to Meter. Travis Bradley
3/4" Copper Tubing-K Unit 18, Ppress Male Adapter Unit 2, 3/4" meter coupling Unit 2,
3/4" Ball Valve Unit 1

METER HISTORY

[illegible]

CHARGE OUTS