

APPLICATION No.: 13177				TAP CLEARED 8828-2966			
LOCATION:	872 So. First	DATE	BEF.	AFT.	REMARKS	✓	
OWNER:	Jaw P. & Mary E. Minard						
MEASURES:	5/8" Lead	01-01-1911	1/10/12	8:00	2012-0201647		
	N from Cove. RD	86.0					
	W from E line First	6.4					
	S from N line House	13.0					
6/23/88: Renewed from 1 ft. outside curb stop to prop line.							
Stock: 8ft. 3/4" copper tubing 1-3/4" curb stop							
1 - Caldwell stop box 2-3/4x5/8 lead to cop adapt. xxs.							
=====							
1/10/12 - City crew renewed water service from main to property line							
33 ft -3/4" copper tubing; 1 -3/4" curb stop, 1 Caldwell stop box; 1 -5/8" x 3/4" lead to cop adapt. xxs;							
1 -5/8" x 3/4" Fig 413; Tap cleaned. Foreman: Dan Perry							
1/10/12 - City crew repaired section of sewer main, damaged while working on water service							
3 ft - 10" PVC pipe; 2 -10" clay to pvc fernco's							
Foreman: Dan Perry							
3/24/15 farland corp renewed water service frtom curb stop to meter							
inspection p reynolds							

[illegible]

CHARGE OUTS

[illegible]