LOCATION: 31 Grape St APPLICATION No.: 13191	TAP CLEARED			
	DATE	BEF.	AFT.	REMARKS
OWNER:				
MEASURES: March 9, 1910  E from Page St 53.5' S from N Line Grape St 7.0' E from W line house 7.6'  6-13-2018: Lead service line replacement prographase 1, Contractor P. Gioioso & Sons TYPE CU, Diamter linch, Water Pressure 70  Distance from main to curb stop 18.8' Distance curb stop to meter 22.4' Distance from curb face to curb stop 1.6' Depth of service 4.1' Total length of new pipe installed 41.2' Curb stop replaced: YES Size 1" Corporation replaced: YES Size 1" Ball Valve furnished:YES Size 1"	e m			

