

OWNER: E. Clark

MEASURES:	5/8"	L lead	Mar. 16, 1910
	E from	Ocean	85.0 ft.
	S from N line	Arnold	7.0 ft.
	W from E line	House	13.3 ft.

Oct. 31, 1961 Renewed from $\frac{1}{2}$ ft. outside curb stop to property line.

7 ft. - $3\frac{1}{4}$ " copper tubing; 1- $3\frac{1}{4}$ " cop to cop stop,
fig. 415 R.H.; 2# wiping solder.

10/25/85: Renewed from $\frac{1}{2}$ " outside curb stop to inside cellar.
(12 ft. ins. prop line) Stock" 20 ft. $\frac{3}{4}$ " copper tubing
1 - $\frac{3}{4}$ " curb stop 1 - Caldwell stop box 1 - $\frac{3}{4}$ x $\frac{5}{8}$ lead to
cop adapt. xs.

11/23/89: Renewed from main to a point 1 ft.
Stock: 1ft. 3/4" copper tubing 1-3/4x5/8 lead to cop adapt. xxs
1 - 3/4" Fig.413

8/19/92: Chap 90 project Pavao cont. renewed from main to curb stop
supplied all stock & labor 21.0ft 3/4" copper tubing
1-3/4" curb stop 1-Caldwell stop box 1-3/4x5/8 Fig 413
I nsp J Rodrigues

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

11/23/89:	TAP REAMED
-----------	------------

8/19/92: tap reamed

METER HISTORY

CHARGE OUTS

[illegible]

CHARGE OUTS