


APPLICATION No.: 13224

TAP CLEARED 

LOCATION: 48 Woodlawn

OWNER: F.C. Edmonson

MEASURES: 5/8"

W from	Brock Ave.	467.2 ft.
N from S	Woodlawn	6.5 ft.
E from w	house	11.7 ft.

11/27/07 - Renewed from main to inside cellar (8 ft. inside property line).  
22 ft - 3/4" copper tubing; 1 -3/4" curb stop; 1 Caldwell stop box; 1 -5/8" X 3/4" Fig. 413; Tap Reamed.  
Broke sewer service & repaired it with 12 ft -6" PVC & 2 -6: Clay to PVC Ferco's Foreman: D. Monty

11/28/07 - City installed new concrete sidewalk & driveway paid by owner. Owner charged \$1,785.57  
Foreman: Joe Costa

DATE

BEF.

AFT.

REMARKS

9-19-01

7:45 A

2001-370-9451

10/27/07

8:11 AM

2007-410-9483

11/27/07

Tap Reamed

[illegible]

## CHARGE OUTS

[illegible]