

APPLICATION No.: 13238

TAP CLEARED

LOCATION: 61 Bay St.

OWNER: Camila Costa

MEASURES: 5/8"

L lead

Mar. 30, 1910

E from

Ward St.

46.4 ft.

S from N line

Bay St.

7.0 ft.

E from W line

house

2.0 ft.

Jan. 9, 1975 Renewed from 6" outside curb stop to inside cellar.

17 ft. - 3/4" Copper tubing (8 ft. inside)

3/4" Curb Stop Caldwell Stop Box

5/8" x 3/4" lead to cop.

adaptor XXS

- - -

3/19/09 - City crew renewed service from main to curb stop, due to leak

20 Ft - 3/4" copper tubing; 1 -3/4" curb stop; 1 Caldwell stop box;

1 -5/8" x 3/4" Fig. 413. Tap Reamed. Foreman: Danny Perry

DATE

BEF.

AFT.

REMARKS

3/18/09

2009-1203702

3/19/09

Tap reamed

METER HISTORY

CHARGE OUTS

[illegible]