| APPLICATION No.: 13249   | TAP CLEARED |      |      |         |
|--|-------------|------|------|---------|
| LOCATION: 79 Nelson St   | DATE        | BEF. | AFT. | REMARKS |
| OWNER:   |             |      |      |         |
| MEASURES: April 11,1910  E X Crapo St S X N Line Nelson St E X W Line House  07/28/2020 Lead Service Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water pressure 100 Distance from main to curb stop (ft) 25.5 Distance curb stop to meter (ft) 14.2 Distance from curb face to curb stop (ft) 1.8 Depth of service (ft) 4.1 Total length of new pipe installed (ft) 39.7 Curb stop replaced: yes size 1" Corporation replaced: yes size 1" Ball valve replaced: yes size 1" |             |      |      |         |

