

APPLICATION No.: 13297

LOCATION: 304 Davis St

TAP CLEARED

OWNER: _____

31-313

MEASURES:

E X W line Brook 226.0 ft

N X S line Davis 9.0 ft

E X W line House 9.0

1" Copper Service

06/05/2018 Lead Service Line Replacement Program

Phase 1, Contractor P. Gioioso & Son

Type CU, Diameter (in) 1, Water pressure 70

Distance from main to curb stop (ft) 11.2

Distance from curb stop to meter (ft) 17.0

Distance from curb face to curb stop (ft) 1.9

Depth of service (ft) 3.6

Total length of new pipe installed (ft) 11.2

Curb stop replaced yes size 1"

Corporation replaced yes size 1"

Ball valve furnished no size 3/4"

Remarks: 1" to 3/4" union installed 1.0 lf from
curb stop

DATE

BEF.

AFT.

REMARKS

11/20/85 Ream

10/05/06

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

