


APPLICATION No.: 13386TAP CLEARED LOCATION: 131-133 ReynoldsOWNER: Laster

MEASURES:

3/4"N frm Peckham St.

67.5

E from W line Reynolds

8.5

S from N line body of house

5.0

1-8-1910

DATE

BEF.

AFT.

REMARKS

2-25-94 940802159

2/11/95: tap reamed

3/21/95

9513-00186

Clear Elect.

3/29/95: TAP REAMED

Oct. 29, 1973 Renewed from  $\frac{1}{2}$  ft. outside curb stop to property line.9 ft. -  $\frac{3}{4}$ " Copper tubing  $\frac{3}{4}$ " Hays curb stop  
Caldwell Stop Box2/25/94: Renewed from  $\frac{1}{2}$ ' outside curb stop to prop lineStock: 10ft  $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ " curb stop1-Caldwell stop box 2- $\frac{3}{4}$ x $\frac{5}{8}$  lead-cop adapt.xxsNote: This service should be renewed from the street to curb stop in spring  
before sidewalk is blacktopped. - Poor pressure

DIG SAFE # MAS 61044

2/11/95: Renewed from main to a point 2ft in front of main

Stock: 2ft  $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ x $\frac{5}{8}$  lead-cop adapt.xxs1-  $\frac{3}{4}$ x $\frac{5}{8}$  Fig 413

March 29, 1995: Renewed from main to ins.cellar (8 ft ins.prop

line) Stock: 24 ft  $\frac{3}{4}$ " copper tubing( OWNER SUPPLIED 16ftOF COPPER) 1- $\frac{3}{4}$ " curb stop same Caldwell stop box1- $\frac{3}{4}$ x $\frac{5}{8}$  Fig 413see  
(other side)



[illegible]

## CHARGE OUTS

[illegible]