	APPLICATION No.: 13394	TAP CLEARED			
LOCATION:_	100 Nelson St	DATE	BEF.	AFT.	REMARKS
OWNER: _					
MEACUREC	May 24,1910 E X Crapo St N X S Line Nelson St E X W Line House 11.2 ft "Copper Service 07/27/2020 Lead Service Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water pressure 100 Distance from main to curb stop (ft) 7.2 Distance from curb stop to meter (ft) 12.8 Distance from curb face to curb stop (Ft) 2.0 Depth of service (ft) 4.0 Total lengthof new pipe installed (ft) 20 Curb stop replaced: yes size 1" Corporation replaced: yes size 1" Ball valve replaced: yes size 1"				

