

V

APPLICATION No.: 13421

TAP CLEARED

LOCATION: 201 Eugenia St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

E X Ashley Blvd 245.6 ft
S X N Line Eugenia St 9.0 ft
E X W line House 12.0 ft
1" Copper Service
04/05/2018 Lead Service Line Replacement Program
Phase 1, Contractor P Gioioso & Son
Type CU, Diameter 1in, Water pressure 68
Distance from main to curb stop (ft) 21.5
Distance from curb stop to meter (ft) 13.0
Distance from curb face to curb stop (ft) 2.3
Depth of service (ft) 3.8
Total length of new pipe installed (ft) 37.5
Curb stop replaced: yes size 1"
Corporation replaced: yes size 1"
Ball valve furnished: yes size 1"
Remark: 21.5 ft main to curb stop, 12.0 ft curb
stop to house, 1.0 ft wall tickness to meter, 3.0
WHIP

[illegible]