

APPLICATION No.: 13483

## TAP CLEARED

LOCATION: 30 Rodney St.OWNER: Rose Silva

DATE

BEF.

AFT.

REMARKS ✓

4-30-01

11:30

2001-170-7371

MEASURES: 5/8" H lead July 5, 1910

W from East French Ave. 386.4 ft.

N from S line Rodney St. 9.5 ft.

E from W line house 8.6 ft.

-----  
September 7, 1965 Renewed from the main to a point 2 ft. inside the curb stop.

11 ft. of 3/4" copper tubing 1 3/4" cop. to cop. stop

1 5/8" reused corporation cplg. 1 lb. wiping solder

-----  
12-15-2000 Tilcon Const. renewed from curb stop to property line.

Stock: 10 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,

1 - Caldwell Stop Box, 1 - 5/8" x 3/4" lead to cop. adapt.XXS.

Dug service close to main was leaking. Tightened tap coupling and nut on tap. Tilcon did work.

[illegible]

## CHARGE OUTS

[illegible]