

APPLICATION No.: 13533

## TAP CLEARED

LOCATION: 39 Ingraham

OWNER: Arsene Denault

MEASURES:

5/8<sup>th</sup>

E from.

Acush Ave.

108.7 ft.

S from N line

Ingraham

9.1 ft.

W from E line

house

16.0 ft.

Dec. 24, 1973 Renewed from 6" outside curb stop to property line.

10½ ft. - 3/4" Copper tubing 3/4" Hays curb stop  
2 wipe joints

— — —

August 22, 1974 Renewed leak at wipe joint outside curb stop.

1 ft. - 3/4" Copper tubing      5/8" x 3/4" lead to copper  
adaptor

No sidewalk cut - used same trench as previous leak  
12/24/73 not yeat cemented.

— — —

k/17/79: Renewed from main to the property line. 32 ft.-  
3/4" copper; 3/4" curb stop; 3/4" x 5/8" Fig. 413;  
Caldwell stop box; 5/8" x 3/4" lead-cop. adapt. XS

Serv. ripped up by Maasey  
Tug - while digging  
sidewalk - Work done before

[illegible]

## CHARGE OUTS

[illegible]