

APPLICATION No.: 13595

TAP CLEARED ✓

LOCATION: 402 Sawyer S.E. Cor. ¹⁰⁹² County

OWNER: William Tremblay

MEASURES:

3/4"

E from

County

33.0 ft.

N from S line

Sawyer

7.9 ft.

W from E line

House

28.2 ft.

7/13/88: Renewed from main to prop line. Stock: 16 ft. 3/4"
copper tubing 1-3/4" curb stop 1-3/4 x 3/4 cop to cop cplg. comp
at prop line. 1-3/4 x 5/8 Fig. 413 1 Caldwell Stop box, comp.

NOTE: SERVICE IS ALL COPPER MAIN TO CELLAR-----NO RECORD FOUND
FOR COPPER PROP LINE INTO CELLAR.) → See Back Card.

June 2003 Renewed from new 8" main to a point 2 ft.
Stock: 2 ft. 3/4" copper tubing; 3/4" x 3/4" cop-cop
cplg., comp; 3/4" Corp. tap

DATE

BEF.

AFT.

REMARKS

7/13/88: TAP REAMED

7/13-8828-2466

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 13595 3/4"

LOCATION: 402 Sawyer St. S.E. Cor. County St.

OWNER: P.N. Leduc

MEASURES: $3/4"$

E from	County	33.0 ft.
N from S line	Sawyer	7.9 ft.
W from E line	House	28.2 ft.

May 6, 1974 Renewed from 6" outside curb stop to inside cellar.

16 ft. - 3/4" Copper tubing (8 ft. inside)

3/4" Curb stop Stop Box

1 wipe joint

— — —

TAP CLEARED

[illegible]

[illegible]

CHARGE OUTS

[illegible]