

APPLICATION No.: 13642 5/8"

TAP CLEARED

LOCATION: 110 Cottage St.OWNER: Roland DumasMEASURES: 5/8"

S from

Maple

130.7 ft.

W from Eline

Cottage

7.0 ft.

N from S line

House

15.3 ft.

April 4, 1961 Renewed from $\frac{1}{2}$ ft. outside curb stop to 3' inside
curb stop $3\frac{1}{2}$ ft. of $\frac{3}{4}$ " copper tubing
 $\frac{3}{4}$ " copper to copper stop, fig. 415
1 C. I. stop box bottom

June 2, 1977: Renewed from curbstop to the line. 7 ft.- $\frac{3}{4}$ " copper;
 $\frac{5}{8}$ " x $\frac{3}{4}$ " lead connector XS; Caldwell stop box;

checked out by Dumas

5/29/86 19 ft. pump

10/30/97: Renewed from amin to curb stop. Stock: 22 ft. $\frac{3}{4}$ "
copper tubing, same curb stop, same stop box, 1- $\frac{5}{8}$ x $\frac{3}{4}$ Fig.413

Street reconstruction-----

DATE

BEF.

AFT.

REMARKS

10/30/97

tap reamed

039A3D 9AT

[illegible]

CHARGE OUTS