

121 Weld St.  
2001

APPLICATION No.: 13673

LOCATION: Purchase

OWNER: FIRE SUPPLY

MEASURES:

6" Gate

S Clark 154.4 ft.  
E from W line Purchase St. 6.7 ft.  
S from N line bldg. 153.9 ft.

Jan. 4, 1980 Renewed from existing 16" x 16" x 8" tee with 1 ft. - 8" C.I.C.L. Ductile Pipe

8" Clow Gate Valve, mech.

4.5 ft. - 8" C.I.C.L. Ductile Pipe

8" x 8" x 4" Tee (for 4" service)

1.6 ft. - 8" C.I.C.L. Ductile Pipe

8" x 6" Reducer, Mech.

1.8 ft. - 6" C.I.C.L. Ductile Pipe

6" Clow Gate Valve, Mech.

Measures of 8" Clow gate valve, mech.

S x S line Clark St. 158.0 ft.

E x W line Purchase St. 13.8 ft.

E x E line Bldg. 14.4 ft.

Measures of 6" Clow Gate valve, mech.


S x S line Clark St. 155.0 ft.

E x W line Purchase St. 4.2 ft.

E x E line Bldg. 4.8 ft.

TAP CLEARED

DATE BEF. AFT. REMARKS



# 13673-6"  
FIRE SUPPLY

# 29840-4"

[illegible]

## CHARGE OUTS

[illegible]

APPLICATION No.: 13673

TAP CLEARED

LOCATION: 2001 Purchase W.S. of S. Clark

OWNER: \_\_\_\_\_

MEASURES:

6"	Chap gate	
S from	Clark	154.4
E from	Wline Purchase	6.7
S from	N line bldg	153.9

**FIRE**

**SUPPLY**

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]