

Service Killed

APPLICATION No.: 13678

TAP CLEARED



LOCATION: 12 Woodlawn

OWNER: Antero Dos Santos

MEASURES: 5/8"

W from	Brook Ave.	95.0 ft.
N from S	Woodlawn	8.0 ft.
W from E	house	2.4 ft.

7/16/ 79: Renewed from 6" outside curbstop to a point 3.6 ft. inside. 4 ft.-3/4" copper; 3/4" curb stop; Caldwell stop box; 2-5/8" x 3/4" lead-cop. adapt. XS;

12/8/06 Renewed from main to property line. Stock: 14" 3/4" copper tubing; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4" lead-cop adapt. XXS; 5/8" x 3/4" Fig. 413

Also repaired 6" sewer service on street. Stock: 5 ft. 6" PVC pipe; 1-6" rubber cplg. clay-PVC Bento

4/20/2011 RJ Canessa Killed this service at the tap.
Inspected by Percy.

DATE

BEF.

AFT.

REMARKS

9-19-01

7:45A

2001-270-9451

12-12-06

10:55

2006-490-5599

12/8/06

8:30 AM

2006-490-6426

12/8/06

Tap reamed

[illegible]

CHARGE OUTS

[illegible]