

APPLICATION No. 13704 5/8"

TAP CLEARED

LOCATION: 397-399 Cedar Grove

DATE

BEF.

AFT.

REMARKS

OWNER: E. Patestea

8/26/71

Reamed

MEASURES: 5/8"

E from Reynolds 142.0 ft.

S from N line Cedar Grove 9.0 ft.

E from W line House 11.2 ft.

2-23-93

93090596

Jan. 8, 1960 Renewed 1 ft. outside to 2 ft. inside curb stop.

3 ft. - 3/4" copper tubing; ~~1 - 3/4" copper tubing;~~  
2# wiping solder; 1 - 3/4" cop to cop stop, fig. 415;

Aug. 26, 1971 Renewed from the main to 3 ft. from the main.

3 ft. - 3/4" Copper tubing 3/4 x 3/4" Fig. 413  
1 wipe joint

July 7, 1975 Renewed from 6" outside curb stop to 6 1/2 ft. inside.

7 ft. - 3/4" Coppertubing 3/4" x 5/8" lead to  
Buffalo Stop Box copper adaptor XS12/21/78: Renewed 5 ft. from main. 5 ft. - 3/4" copper;  
5/8" x 3/4" lead to cop. adapt.XS; 5/8" x 3/4" Fig. 413;

12/21/78

Reamed

2/23/93: Renewed from lft outside curb stop to prop line

Stock: 10ft 3/4" copper tubing 1-3/4 curb stop 1-Caldwell stop  
box 2-3/4x5/8 lead-cop adapt.XS=====9/13/93: Chap 90 Project Medeiros & SonCont renewed from new  
8" main to curb stop All stock supplied by Cont.24.3 ft 3/4" copper tubing same curb stop same Caldwell stop box  
1-3/4" corporation tap Insp. M Rose III



## METER HISTORY

## CHARGE OUTS

[illegible]