

APPLICATION No.: 13715

TAP CLEARED

LOCATION: 139-141 Reynolds

OWNER: \_\_\_\_\_

MEASURES:

10-25-1910

5/8"

N from Peckham

139.3

E from W line Reynolds

8.8

N from S line house

12.5

-----  
February 1, 1960 Renewed from a point 4 ft. inside curb stop to  $\frac{1}{2}$   
ft. outside curb stop.

1 3/4" cop. to cop. stop

2 lbs. wiping solder

-----  
11/1/06 - Caliacco Corp renewed from main to property line -18.5 ft

✓ 2/25/2021 - Water renewal - Curb stop to meter

Done by DPI - Rui Martins

(3-4)" ball 3/4" ball valve 1-each, MtXFS 90 3/4" male

thread x female - (3-4)" sweat 90 1-each, CI-CRB-B Cast

Iron Curb stop boxes 1-each, Cop box of 3/4" copper tubing

(3-4)" 60 ft coils 13-feet

1 - METER BLANK

[illegible]

## CHARGE OUTS

[illegible]