

APPLICATION No.: 13758

LOCATION: 163 Frederick St

OWNER:

31-313

MEASURES:

E from Brock Ave 102.5'

S from N Line Frederick St 8.3'

E from W Line House 12.5'

1" COPPER SERVICE

8-23-2019: Lead service line replacement

program phase 1, Contractor P.Gioioso & Sons

TYPE: CU, Diameter 1inch, Water Pressure 100

Distance from main to curb stop 25'

Distance curb stop to meter 16.3'

Distance from curb face to curb stop 2.5'

Depth of service 4.3'

Total length of new pipe installed 16.3'

Curb stop replaced:NO Size 3/4"

Corporation replaced:NO Size 3/4"

Ball Valve furnished: YES Size 1"

Remarks; 1- 3/4" union installed hwere shown

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

10/13/86:

Tap

reamed

7/31/97: Tap

Tap

reamed

[illegible]

CHARGE OUTS

