

APPLICATION No.: 13784

TAP CLEARED P2301201

LOCATION: 115 Dunbar St.

OWNER: Mario Vieira Norte

MEASURES: 5/8" H lead Oct. 21, 1910

E from Dartmouth St. 93.7 ft.

S from N line Dunbar St. 9.4 ft.

E from W line house 11.9 feet.

AUG 1 - 1982 --Renewed from 6" outside curbstop to a point 3.5 ft. inside. 4.0 ft.-3/4" copper; 2- 5/8" x 3/4" lead-cop. adapt. XXS; 3/4" curb stop; stop box;

2/22/90: Renewed from main to a point 1 ft.

Stock: 1ft 3/4" copper tubing 1-3/4x5/8 lead to
cop adapt. xs 1-3/4x5/8 Fig. 413

3-22-2000 Renewed from main to property line. Stock:
35 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,
1 - Caldwell Stop Box, 1 - 5/8" x 3/4" lead to cop. adapt.
XKS, 1 - 5/8" x 3/4" Fig. 413. Tilcon to maintain cut.

10-5-2000 Renewed from property line into cellar. Stock:
9 ft. - 3/4" Copper tubing, 1 - 3/4" x 3/4" cop to cop cplg., comp.

DATE	BEF.	AFT.	REMARKS
			✓

2/22/90: TAP REAMED

3-22-2000 Tap reamed

10/5/00 2000 410 7270

4-30-01	11:30	2001-170-7401
---------	-------	---------------

[illegible]

CHARGE OUTS

[illegible]