

325

APPLICATION No.: 13859

TAP CLEARED

LOCATION: 343 Tarklin Hill Rd.

DATE

BEF.

AFT.

REMARKS

OWNER: St. Killian R.C. Parish

MEASURES: 5/8"

60.0 EX TISBURY ST

W from

Pine Grove St.

266.0 ft.

S from N line

Tarklin Hill Rd.

10.2 ft.

E from W line

House

1.5 ft.

June 26, 1950 Leak at tap.

1 ft. of 3/4" copper tubing

1 3/4" cop. to 3/4" I.B.f. cplg.

12/20/78: Renewed from 7 ft. outside curbstop to prop. line (lead-cop. adapt. 6 ft.  
 17 ft.-3/4" copper; 3/4" curb stop/ 2-5/8" x 3/4" lead-  
 cop. adapt. XS; Caldwell stop box; S x N curb stop)

9/14/88 leak inside foundation - was not completely off - shut off at curb by M. Rose

NOT READING SINCE 1988

INACTIVE SER

[illegible]

## CHARGE OUTS

[illegible]