

65

APPLICATION No.: 1386

TAP CLEARED

8432-1710

LOCATION: 57 Smith

OWNER: ~~Henry P Onley~~

MEASURES:

3/4"

E from

Summer

19.1 ft.

S from N line

Smith

6.7 ft.

W from E line

House

12.6 ft.

9/30/77-Renewed 5 ft. from main to curb stop. 3/4" copper; 3/4" x 3/4" adapt. XS
Fig. 413; tap reamed; 3/4" x 3/4" lead to cop. adapt. XS

12/19/77: Renewed 6" outside curbstop to property line. 6 ft.-3/4" copper; 3/4" curb stop; 2-5/8" x 3/4" lead to cop. adapt. XS; Caldwell stop box;

1/31/78: Renewed from main to a point 4 ft. from main. 4 ft.-3/4" copper (reused lead connectors & Fig. 413)

12/29/78: Renewed from main to curb stop. 20 ft.-3/4" copper.

8/9/84 Renewed from curb stop to 2 ft. inside of property

Stock: 7ft. 3" copper tubing 3/4 1 3/4 curb stop

1 Caldwell stop box 1 3/4 x 5/8 lead to cop adapt. XXS

11-12-98 Renewed from 1/2' outside curb stop to ins. cellar.

(5 ft. ins. prop. line) Stock: 14 ft. - 3/4" Copper tubing,

1 - Caldwell Stop Box.

DATE

BEF.

AFT.

REMARKS

9/30/77

reamed

11-12-98

984605559

[illegible]

CHARGE OUTS

[illegible]