

APPLICATION No.: 13872

TAP CLEARED

LOCATION: 305 MillOWNER: Dennis L. SullivanMEASURES: 5/8"

W from	Newton	108.0 ft.
S from N line	Mill-	6.6 ft.
E from W line	Body of House	15.5 ft.

*1-29-93 METER INSTALLERS BROKE SERV.*1/29/93: Renewed from  $\frac{1}{2}$ ' outside curb stop to prop lineStock: 6.5ft  $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ " curb stop1-Caldwell stop box 2- $\frac{3}{4}$ x $\frac{5}{8}$  lead-cop adapt.xs

10-29-99 DW White renewed from main to curb stop.

Stock: 21 ft. -  $\frac{3}{4}$ " Copper tubing, 1 -  $\frac{3}{4}$ " Curb Stop1 - Caldwell Stop Box(same), 1 -  $\frac{5}{8}$ " x  $\frac{3}{4}$ " Fig. 413.

DW. White to maintain cut.

08/6/07 - Renewed from main to curb stop by private contractor.

Charged \$40.78 for inspection (\$30) and 2 couplings (10.78)

Blank returned - MES

7/26/07 - Nelson Cardoso renewed service from a point 4.5 ft  
inside curb stop to inside cellar10 ft -  $\frac{3}{4}$ " copper; 1 coupling

DATE

BEF.

AFT.

REMARKS

10-29-99 Tap reamed

[illegible]

## CHARGE OUTS

[illegible]