

APPLICATION No.: 13908

TAP CLEARED

LOCATION: 22 Jenny LindOWNER: Frank H OhildaMEASURES: 5/8"

S from

Kempton

373.7 ft.

W from E line

Jenny Lind

7.2 fr.

S from N line

House

4.2 ft.

12/28/78: Renewed 6" outside to 5.6 ft. inside curbstop.
6 ft. - 3/4" copper; 3/4" curb stop; 2-5/8" x 3/4" lead to
cop. adapt. XS; Caldwell stop box;

5/3/12 - City crew renewed water service from curb stop
to meter (1/2 foot outside curb stop to 19 ft inside
property line)

25 ft - 3/4" copper tubing Foreman: Danny Perry

DATE

BEF.

AFT.

REMARKS

5/3/12

8:00

2012-1711312

[illegible]

CHARGE OUTS

[illegible]