

APPLICATION No.: 13930

TAP CLEARED

LOCATION: 24 Maple View Terrace

OWNER: Edward T. Sears

MEASURES: 5/8"

W from

Tremont

218.0 ft.

N from S line

Maple View Ter.

4.2 ft.

W from E line

House

7.3 ft.

Nov. 6, 1974 Renewed from 6" outside curb stop to property line.

7 ft. - 3/4" Copper tubing 3/4" Curb Stop
1/2" x 5/8" lead to copper 1 wipe joint
adaptor

- - -

March 9, 1982 Retapped new 6" main. Renewed from the main to a point 1 ft. from the main.

3/4" copper tubing - 1 ft. 3/4" Corporation
1 - 5/8" x 3/4" lead to cop adapt XS

- - -

7/31/92: Pavao Const. renewed from main to curb stop

All stock & labor by Pavao Const. 9.0ft 3/4" copper tubing

1-3/4" curb stop 1-Caldwell stop box

NOTE: wipe joint still at prop line was not insp. by NB water
info supplied by engineer on site. Insp. J Rodrigues & L. Souza
Chap 90 proj.

[illegible]

CHARGE OUTS

[illegible]