

LOCATION: 322 Clinton St.OWNER: Irving CommMEASURES: 5/8"

W from	James	89.4 ft.
N from S line	Clinton	7.0 ft.
W from E line	House	5.0 ft.

10/27/86: Renewed from $\frac{1}{2}$ ' outside curb stop to a point 4.0 ft.
 Stock: 4.0 ft. $\frac{3}{4}$ " copper tubing 1 - $\frac{3}{4}$ " curb stop
 1 - Caldwell stop box 2 - $\frac{3}{4}$ x $\frac{5}{8}$ lead to cop adapt. xs.

9-1-2000 Renewed from main to curb stop. Stock:
 9 ft. - $\frac{3}{4}$ " Copper tubing, 1 - $\frac{3}{4}$ " Curb Stop,
 - $\frac{3}{4}$ " Caldwell Stop Box, 1 - $\frac{3}{4}$ " Corporation tap.
 Silva Const. to maintain cut.

9-25-2000 Silva Construction renewed from 14 ft. ins. property
 line to ins. cellar. Stock: 22 ft. - $\frac{3}{4}$ " Copper tubing,
 1 - $\frac{3}{4}$ " Curb Stop(same), 1 - Caldwell Stop Box (same)
 Silva Const. to maintain cut.

9-25-00 Renewed from curb stop to ins. cellar. (14 ft. ins. prop.
 line) Stock: 22 ft. - $\frac{3}{4}$ " Copper tubing, 1 - $\frac{3}{4}$ " Curb Stop(same)
 1 - Caldwell Stop Box(same) Frankl. Const. to maintain cut.

DATE

BEF.

AFT.

REMARKS

25

10/9/59

SET
OUT

SIZE

MAKE

NUMBER

READING

TEST

REMARKS

5/8

Calmet

1662323