

APPLICATION No.: 13954

TAP CLEARED

LOCATION: 316 Maxfield

DATE

BEF.

AFT.

REMARKS

OWNER: Vocational High School

MEASURES: 4"

4" Chap. gate

E from

Emerson

23.5 ft.

N from S line

Maxfield

6.2 ft.

W from W line

brick bldg.

29.8 ft.

NOv. 6, 1991 West of 90° Bend 1" service killed at tap at 4" domestic main. See map for ties. (C on map) M. Rose

NOv. 26, 1991 Cut out old 4" gate in bldg. (Old garage being renovated) also solid sleeve. Tied in with 4.0 ft. pc. of 4" ductile pipe & 2 - 4" Smith Blair Cplgs. Located N x south wall 21.5 ft. & 25.5 ft.

Dec. 2, 1991 In Yard - East end of service removed old 4 way 4" cross and W.Side 1/8 Bend killing 2" service. Replaced with mechanical 4" 1/4 Bend (90°), 2.5 ft. pc. - 4" ductile SS to tie in 4" cplg. 2.5 ft. pc. 4" ductile pipe W.S. to 1/8 Bend 4" Mech. installed at existing 4" pipe.

Measures: 4" 1/4 Bend - S x Building 13.0 ft.

4" Smith Blair #441 cplg: S x Bldg. 15.5 ft.

4" 1/8 (45° Bend - W x new mech. 90° Bend 3.0 ft.

Dec. 3, 1991 Cut out 4" x 4" x 2" tapping sleeve and old 3/4" tap just inside south wall & north of tunnel (in garage) replaced with 3.5 ft. pc. 4" ductile pipe, 2 - 4" Omni cplgs. Located 1.0 ft. & 4.5 ft. N x south wall. (on doorway south wall of garage)

Dec. 4, 1991 Replaced broken 4" gate valve SS Meter Pit with top section (bonnet) of old gate dug up from inside garage, included valve, spindle & bolts.

1 - #10 Gate Box, compl.

INACTIVE SERVICE



[illegible]

## CHARGE OUTS

[illegible]

APPLICATION No.: # 13954

## TAP CLEARED

LOCATION: 316 Maxfield St.

OWNER: Vocational High School

## MEASURES:

Dec. 5, 1991 Cut in new 4" Mueller gate in yard S.S. tunnel tied with 1.0 ft. pc.  
4" ductile each side, 2 - 4" Smith Blair #441 cplgs. Replaces removed gate in  
garage.

Measures of 4" Mueller gate valve, mech:

S x wall 11.0 ft.

Ties: S/W x cor. bldg. 33.0 ft.

N/W x hydrant 26.5 ft.

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]