

14009

TAP CLEARED

1055 59 So. Water

Samuel Roiflan

(INACTIVE SER)

 $3/4''$

Cove	299.7 ft.
Water	6.9 ft.
house	12.9 ft.

JUL 10 1981 - Renewed from 8" outside curb stop to inside cellar. 16 ft.-3/4" copper (6 ft. inside); 3/4" curbstop; Caldwell stop box; 3/4" x 3/4" lead-cop. adapt. flared;

Nov. 8, 1983 J.F. KENNEDY HWY. PROJ. Dow Co. renewed
from the new 8" Water St. main to the curb stop.
11 ft. - 3/4" copper tubing 3/4" Mueller tap
3/4" curb stop Reused same stop box
Box in same location
Forte Bros. supplied all stock; Insp. J. Rodriques

Shutoff by Deant Non Payment & Leak 12/4/90

[illegible]

CHARGE OUTS

[illegible]