

APPLICATION No.: 14043

TAP CLEARED

LOCATION: 210 James

OWNER: N. Wiley

MEASURES: 5/8"

S from

W from E line

S from N line

Kempton

James

house

113.6 ft.

8.2 ft.

8.4 ft.

DATE

BEF.

AFT.

REMARKS

3/9/77

Reamed

8/30/01

8:30 AM

2002-

Jan. 20, 1972 Renewed from $\frac{1}{2}$ ft. outside curb stop to cellar.

22 ft. - $\frac{3}{4}$ " Copper tubing $\frac{3}{4}$ " curb stop
1 wipe joints

March 9, 1977 Renewed from the main to a point 2 ft. from the main.

2 ft. - $\frac{3}{4}$ " Copper tubing $\frac{3}{4}$ " x $\frac{3}{4}$ " Fig. 413
 $\frac{5}{8}$ " x $\frac{3}{4}$ " lead to copper adaptor XS

August 30, 2002 - Renewed from main to curb stop; 22ft.- $\frac{3}{4}$ " copper tubing, 1- $\frac{3}{4}$ " curb stop, 1-Caldwell stop box, 1- $\frac{5}{8}$ x $\frac{3}{4}$ Fig. 413; tap reamed

9/10/08 - Perrina Construction - West End Water Rehab Contract #4
Renewed service from main to a point 5 ft
5 ft - 1" copper tubing; 1 -1" corp. tap; 1 - 1" x $\frac{3}{4}$ " reducer
inspected by Tim Ives, CDM

[illegible]

CHARGE OUTS

[illegible]