

APPLICATION No. 14113

TAP CLEARED

C-82

LOCATION: 184 Myrtle

OWNER: Jas. & O Wilde

CLEAR ELECT.

MEASURES:

3/4"

S from

Coggeshall

60.4 ft.

W from E line

Myrtle

8.3 ft.

N from S line

House

14.3 ft.

DATE

BEF.

AFT.

REMARKS

4/23/92

9204

1280

1/24/92

TAP REAMED

9/19/00

2000 1903111

9-20-2000 Tap reamed

Dec. 27, 1956 Renewed from curb stop to a point 3 ft.
inside curb stop.

3 ft. - 3/4" Copper tubing 2# wiping solder

March 3, 1981: Renewed from 6" outside curbstop to the property line.

6.5 ft.-3/4" copper

1-3/4" curb stop Caldwell stop box

2-5/8" x 3/4" lead-cop. adapt. XXS

1/24/92: Renewed from main to a point 1ft Stock: 1ft 3/4" copper
tubing 1-3/4x5/8 lead-cop adapt. xxs 1-3/4x5/8 Fig.413

9-20-2000 Renewed from main to inside cellar: (10ft.
inside property line.) Stock: 41 ft. - 3/4" Copper
tubing, 1 - 3/4" Curb Stop, 1 - Caldwell Stop Box,
1 - 5/8" x 3/4" Fig. 413.

10' Patch

974-0693

5000 1280

[illegible]

CHARGE OUTS

[illegible]