

APPLICATION No.: 14115

TAP CLEARED 8605-1018

LOCATION: 85 Hemlock St.

OWNER: Antone Correia Et Ux

MEASURES: 5/8" H lead May22,1911

S from S line Kane St. 23.0 ft.

E from W line      Hemlock St.      9.4 ft.

S from N line      house      10.8 ft.

1/29/86: Renewed from main to inside cellar(11.0 ft. ins. prop line)  
Sotck: 21.0 ft. 3/4" copper tubing 1 - 3/4" curb stop 1 - Caldwell  
stop box 1 - 3/4x5/8 lead to cop adapt. comp. xxs,

2/2/04 Renewed from main to curb stop. Stock: 8 ft.  
3/4" copper tubing; 3/4" curb stop; Caldwell stop box;  
5/8" x 3/4" Fig. 413 Tap reamed

NOTE: FOUND LEAD MAIN TO CURB STOP ON THIS SERVICE!  
Repaired sewer with 4' section of 6" PVC & 2 clay-plastic  
ferncos.

.....

[illegible]

## CHARGE OUTS

[illegible]