

APPLICATION No.: 14143 5/8" L lead

TAP CLEARED

✓

LOCATION: 73 Beech St.

OWNER: Mr. Albert Chace

DATE BEF. AFT. REMARKS

10-21-99 Tap reamed

MEASURES: 5/8" L lead June 14, 1911
 N from Maxfield Street 150.3 ft.
 E from W line Beech 6.3 ft.
 S from N line House 2.0 ft.

March 2, 1945 Leak on outside joint of stop.

- - -

10-21-99 DW White renewed from main to property line.
 Stock: 14 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,
 1 - Caldwell Stop Box, 1 - 5/8" x 3/4" lead to cop. adapt
 XS, 1 - 5/8" x 3/4" Fig. 413, DW White to maintain cut.

8/28/08 west end water main rehab contract #4 perrina constr
 renewed service from main to a point 4.5 ft stock 4.5ft 1 copp
 tubing 1-1 corp tap 1-1x3/4 reducer insp T alves cdm

1.12.2021 JLC Cons. Rewed curb stop to meter
 3/4" copper inspector Percy

N x N line Maxfield St 150.3'
 E x W line Beech St 6.3'
 S x N line house 2'
 N x S line house 28'
 E x E line house 13'
 main to property line 14'
 pipe inside property 11'

METER HISTORY

[illegible]

CHARGE OUTS