

APPLICATION No.: 14187

LOCATION: 417 Park Cor. Smith

OWNER: Wilfred S. Peckham

MEASURES:  $5/8''$

N from

E from W line

S from N line

mith

Park

House

36.0 ft.

8.6 ft.

13.5 ft.

Dec. 20, 1973 Renewed from 6" outside curb stop to  
inside cellar.

20 ft. - 3/4" Copper tubing ( 10 ft. inside)

3/4" curb stop

1 wipe joint

Acushnet Stop Box

— — —

1-12-01 Zenone Const. renewed from main to curb stop. Stock:

10 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell

Sto Box, 1 - 5/8"x3/4" Fig.413. Zenone Const. to maintain cut.

7-31-01 Renewed from curb stop to a point 1 ft. inside curb stop. Stock: 1 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell Stop Box, 1 - 3/4" x 3/4" cop to cop cplg., comp.

Note: Leak caused by DW White.

## TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

1-12-01 Tap reamed

7/31/01

2001-310 3974

[illegible]