

APPLICATION No.: 14197

TAP CLEARED P508-0005

LOCATION: 51 Jenney Lind S.W. Cor. North

DATE BEF. AFT. REMARKS

OWNER: Lora B. Smith

2/19/85 TAP REAMED 8911-3827

MEASURES:

3/4"

N from

Kempton

130.0 ft.

E from W line

Jenny Lind

7.0 ft.

S from N line

House

1.0 ft.

✓ 8/4/80: Renewed from 6" outside curbstop to the prop. line.

5.5 ft. - 3/4" copper; 3/4" curb stop; Caldwell stop box;

2- 5/8" x 3/4" lead-cop. adapt. XXS

✓ 2/19/85: Renewed from main to a point 1.0 ft.

✓ Stock: 1.0 ft. 3/4" copper tubing 1 3/4x5/8 lead to
cop adapt. comp. xxs 1 3/4" Fig. 413

=====

✓ 3/17/89: Renewed from curb stop to ins. cellar(10ft. ins.prop line)

Stock: 16 ft. 3/4" copper tubing.

=====

6/26/08 - West End Water Main Rehab Contract # 4 - Perrina Const.

Renewed water service from main to property line

11 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" curb stop;

1 - 1" x 3/4" reducer. Inspected by Tim Ives, CDM

Mar 1, 2018 Curb stop was loose on the main side and needed to be tightened.

Ronnie A

[illegible]

CHARGE OUTS

[illegible]