

APPLICATION No.: 14292

LOCATION: 56 Jouvette St

OWNER:

31-313

MEASURES: 07/31/2019

1" Copper Service

Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 10

Distance from curb stop to meter (ft) N/A

Distance from curb face to curb stop (ft) 2.3

Depth of service (ft) 4

Total length of new pipe installed (ft) 10

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball valve furnished: no

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

[illegible]

APPLICATION No.: 14292

TAP CLEARED

LOCATION: 56 Jouvette St.

OWNER: A.J. Cohen

MEASURES: 5/8" H lead Aug. 3, 1911

W from County St. 537.0 ft.

N from S line Jouvette St. 9.3 ft.

E from W line house 9.0 ft.

Jan. 27, 1969 Renewed from 6" outside curb stop to the property line.

10 1/2 ft. - 3/4" Copper tubing 3/4" Mueller curb stop
2 wipe joints

- - -

6/2/88: Renewed from curb stop to ins. cellar. (7 ft. ins. prop line) Stock: 12 ft. 3/4" copper tubing 1-3/4x3/4 cop to cop coplg. comp. NOTE: SERVICE BROKEN IN CELLAR BY SPINIELLO CONST. REPAIRED BY SAME. RENEWED FROM 5 FT. INSIDE CURB STOP TO INSIDE CELLAR. =====

Sept 5, 1997: Renewed from main to a point 1.2ft
Stock: 1.2ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt.xxs
1- 3/4 x 5/8 Fig 413 =====

DATE

BEF.

AFT.

REMARKS

9/5/97

973606052

CLEAR ELECTRIC

tap reamed 9/5/97

[illegible]

CHARGE OUTS

[illegible]