

APPLICATION No.: **14304**

TAP CLEARED 8634-3593

LOCATION: 15 Viail

OWNER: Adefard Langlors

MEASURES: $5/8"$

S from	Cove	257.0 ft.
E from W	Viall	9.0 ft.
N from S	house	14.0 ft.

8/9/86: Renewed from main to a point 5.0ft. inside curb stop.
Stock: 13.0 ft. 3/4" copper tubing 1 - 3/4" curb stop
1 - Caldwell stop box 1 - 3/4 x 5/8 lead to cop adapt. xxs
1 - 3/4 x 5/8 Fig. 413

Oct 17, 1995:

Renewed from curb stop to ins.cellar (6ft ins prop line)
Stock: 15ft 3/4" copper tubing same curb stop
same Caldwell stop box

4/9/2019 1" Copper Service
Lead Service Line Replacement Program
Phase 1, Contractor P Gioioso & Son
Type CU, Diameter 1in, Water pressure 100
Distance from main to curb stop (ft) 11
Distance from curb stop to meter (ft) N/A
Distance from curb face to curb stop (ft) 1.5
Depth of service (ft) 4
Total length of new pipe installed (ft) 11
Curb stop replaced: yes size 1"
Corporation replaced: yes size 1"
Ball valve furnished: no

[illegible]

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
9/23/60		5/8	Calmet	1712884					

CHARGE OUTS

