

APPLICATION No.: 14320 5/8" L lead

TAP CLEARED

LOCATION: 82 Campbell St.

OWNER: John W. Whalen

MEASURES: 5/8" 3/4"

W from

N from S line

E from W line

L lead

County

Campbell

House

08-11-1911

181.0 ft.

7.0 ft.

3.7 ft.

DATE

BEF.

AFT.

REMARKS

2/13/04

1 PM

2004-070-4018

2/15/11

Tap repaired

2/15/11 7:30

2011-0801104

July 23, 1969 Renewed from the main to a point
4 ft. inside of the curb stop.

12 ft. - 3/4" copper tubing; 1-3/4" Hays curb stop;
1 wipe joint; 1-3/4" x 3/4" fig. 413 cplg.

- - -

2/13/04 Repaired broken sewer service. Replaced 10 ft
of 6" clay pipe with 6" PVC Stock: 10 ft 6" PVC;
6" Straight Fernco; 6" clay-PVC Fernco

2/15/11 - City crew repaired 6" water main fractured
around existing tap

6 ft -3/4" copper tubing; 1 -3/4" cop-cop cplg comp;
1 -3/4" Corporation Tap; tap ~~cleaned~~ ^{Reamed}; 1 -#226 6" wrap
around. Foreman: Dana Farland

[illegible]