

APPLICATION No.: 14364TAP CLEARED D1373VLOCATION: 17 StapletonOWNER: Peter LopesMEASURES: 5/8"

S from	Cove	205.0 ft.
E from W line	Stapleton	9.0 ft.
S from N line	House	11.0 ft.

JAN 13 1982 - Renewed from 6" outside curbstop to inside cellar. 18 ft.-3/4" copper (8 ft. ins.); 3/4" curb stop; stop box; 5/8" x 3/4" lead-cop. adapt. XXS;

1" Copper Service - - - -

1/15/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 12

Distance from curb stop to meter (ft) N/A

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 4

Total length of new pipe installed (ft) 12

Curb stop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve furnished: NO

Remarks: Sewer runs 4LF parallel and under the 6" WM
3LF between gas pipe and curb, 4.5 LF between gas pipe
and 6" WM

DATE

BEF.

AFT.

REMARKS

[illegible]

This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, characteristic of old paper. A dark binding edge is visible on the left, and a white rectangular object is partially visible at the bottom left corner.

