

APPLICATION No.: 14375

TAP CLEARED

LOCATION: 115 - 117 Jouvette St

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

**OWNER:**

3/24/93

31-313

MEASURES: Sept 14, 1911

W X Crapo St

72.5 ft

S X N Line Jouvette St

9.0 ft

W X E Line House

11.6 ft

1" Copper Service

07/29/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 24

Distance from curb stop to property line (ft) 3

Distance from curb face to curb stop (ft) 1

Depth of service (ft) 4

Total length of new pipe installed (ft) 27

Curb stop replaced: Yes 1"

Corporation replaced: yes size 1"

Ball valve replaced: no

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS