

APPLICATION No.: 14409

TAP CLEARED 8745-0112

LOCATION: 150 Durfee

OWNER: John / Roche

MEASURES:

3/4"

E from	Oakland	292.7
N from S line	Durfee	6.0
E from W line	House	9.0

1/30/79: Renewed from main to 3 ft. front of main.
 3 ft.-3/4" copper; 3/4" x 3/4" Fig. 413; 5/8" x 3/4"
 lead-cop. adapt. XS -----

11-2-87 Renewed from main to property line- 16ft-3/4" copper tubing
 1-3/4"curbstop, 1-Caldwell stop box,1-3/4x5/8 lead to cop adapt xs
 1-5/8x3/4 Fig 413

1/16/07 Stop box was blown out and operating nut checked by:
 Luis J & Derek A -----

1/31/08 - Owner charged \$30 for turn on fee, but Percy
 shut it back off due to the fact that service was
 renewed from property line into bldg with PVC pipe
 instead of copper tubing; NOT ACCEPTABLE over

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

1/30/79		Reamed	✓
---------	--	--------	---

11-2-87		reamed	
---------	--	--------	--

[illegible]

CHARGE OUTS

[illegible]