

APPLICATION No.: 14511

TAP CLEARED 85-35-0616 ✓

LOCATION: 22 Fairmont S.S. W. of Rockdale Ave.

OWNER: Jese C. Galligo

MEASURES: 3/4"

997.9819

Wf rom	Rockdale Ave.	251.0
N from S line	Fairmont	8.0
Ef rom W line	House	13.

August 27, 1985 - Leak before meter - City went there to renew service from curb stop to meter at owners expense - Owner refused to renew - did not want to get a plumb er to install shut off inside.

8/30/85: Renewed from 1 ft. outside curb stop to ins. cellar (10 ft. ins. prop line) Stock: 19ft. 3/4" copper tubing
1 3/4" curb stop 1 Caldwell stop box 1 3/4x5/8 lead to cop
adapt. xxs

=====

7/10/90: Renewed from main to curb stop
Stock: 3/4" copper tubing--10 ft.
1- 3/4" curb stop 1- Caldwell stop box
1- 3/4x3/4 Fig 413

=====

5/27/08 - West End Water Main Rehab Contract # 4 - Perrina Const.
Renewed water service from main to a point 6 ft
6 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer
Inspected by Tim Ives, CDM

DATE

BEF.

AFT.

REMARKS

9028.0058

7/10/90: tap reamed

METER HISTORY

[illegible]

CHARGE OUTS

This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, characteristic of old paper. The left edge of the page shows the binding structure, including the stitching and the inner cover material. There is no text or other markings on the page.