

14515

TAP CLEARED

LOCATION: 217 Eugenia St

DATE _____

BEF.

AFT

REMARKS

OWNER:

31-313

MEASURES: W X Ashley Blvd

61.7 ft

S X N line Eugenia St

8.8 ft

W X E line House

1.1 ft

1" Copper Service

04/26/2018 Lead Service Line Replacement Program

Phase 1, Contractor P. Gioioso & Son

Type CU, Diameter 1in, Water pressure 59

Distance from main to curb stop (ft) 23.5

Distance from curb stop to meter (ft) 17.0

Distance from curb face to curb stop (ft) 3.0

Depth of service (ft) 3.6

Total length of new pipe installed (ft) 43.5

Public 23.5 ft, Private 20.0 ft

Curb stop replaced: yes, size 1"

Corporation replaced: yes, size 1"

Ball valve furnished: yes, size 1"

Remarks: 23.5 ft main to curb stop, 16.0 curb stop to house, 1.0 house to meter, 3 ft whip

[illegible]