

APPLICATION No.: 14642TAP CLEARED 8639-3151LOCATION: 104-6 Clara St.OWNER: Francis A. SylviaMEASURES: 5/8" H lead Apr. 29, 1912E from Brock Ave. 810.0 ft.N from S line Clara St. 8.6 ft.W from E line house 9.0 ft.9/25/86: Renewed from $\frac{1}{2}$ ' outside curb stop to prop line.Stock: 8ft. $\frac{3}{4}$ " copper tubing 1 - $\frac{3}{4}$ " curb stop1 - caldwell stop box 2 - $\frac{3}{4}$ x $\frac{5}{8}$ lead to cop adapt. xxs.

=====

3/23/95:

Renewed from main to ins.cellar (7ft ins.prop line)

Stock: 26 ft $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ " curb stop1- Caldwell stop box 1- $\frac{3}{4}$ x $\frac{5}{8}$ Fig 413

=====

DATE

BEF.

AFT.

REMARKS

3/23/95

9512-04606

3/23/95: tap reamed

METER HISTORY

CHARGE OUTS

[illegible]