

APPLICATION No.: 14658

## TAP CLEARED

LOCATION: 14 Roosevelt St.

OWNER: Jeannette Y. Monteiro

DATE

BEF.

AFT.

REMARKS

7/2/03

Tap reamed

MEASURES: 5/8" H lead May 14, 1912

S from Cove St. 312.2 ft.

W from E line Roosevelt St. 9.5 ft.

S from N line house 14.0 ft.

-----  
April 6, 1962 Rewiped joint at main. Renewed  $\frac{1}{2}$  ft. outside curb stop  
to inside the cellar.

20  $\frac{1}{8}$  ft. of 3/4" copper tubing 2 lbs. wiping solder

1 3/4" copper stop

-----  
3/18/2003 Found service on. Top section of stop box removed.

House condemned & had tenants occupying house. Water was originally  
shut off on Feb. 24, 2000 per Board of Health and was found on  
numerous times since...

Please note: this service was shut off over 1 year & should be  
replaced with copper...

7/2/03 Renewed from main to curb stop. Stock; 26 ft. 3/4" copper;  
3/4" curb stop; Caldwell stop box; 5/8" x 3/4" Fig 413  
Tap reamed

7/15/03 Renewed from curb stop to ins cellar (7 ft ins prop line)  
16 ft 3/4" copper

[illegible]

## CHARGE OUTS

[illegible]