

APPLICATION No.: 14686

TAP CLEARED

LOCATION: 176 Princeton

OWNER: Joseph R. Dufrense

MEASURES:

5/8"

E f r o m

Ashley Blvd.

171.0 ft.

N from S line

Princeton

9.0 ft.

W from E line

House

10.2 ft.

12/13/77: Renewed 6" outside curbstop to 6 ft. inside. 6 $\frac{1}{2}$ ft.-
3/4" copper; 2-5/8" x 3/4" lead to cop. adapt. XS; 3/4" curbstop;
Caldwell stop box

4-3-01 Renewed from main to property line. Stock:
9 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,
1 - 5/8" x 3/4" Fig. 413.

12/4/07 - Water leak happened to be a sewer break.
 Repaired 5 ft - 6" PVC pipe; 2 - 6" clay to PVC Fernco's
 Note: Sewer 1.5 ft under sidewalk - lots of tree roots
 Foreman: D. Monty

5/27/08 - City renewed service from 1/2 ft outside curbstop into cellar. Also repaired section of sewer service
18 ft - 3/4" copper tubing; 1 - 3/4" x 3/4" cop to cop cplg. comp.;
1 - 6" clay to PVC Fernco. Foreman: Dennis Monty
4 ft - 6" PVC; 1 - 6" Straight Fernco

DATE _____

BEF.

AFT.

REMARKS

3123101

4.30	
------	--

pm

2001-120-3453

4-3-01	Tap	reamed
--------	-----	--------

[illegible]

CHARGE OUTS

[illegible]