

APPLICATION No.: 14720

## TAP CLEARED

LOCATION: 241 Hawthorn

OWNER: Elizabeth Leguson

OK ELECTRIC

DATE

BEF.

AFT.

REMARKS

6-4-1999 Tap Reamed

6/4/99 19992307664

MEASURES: 5/8"

E from Rotch 82.0 ft.

S from N line Hawthorn 9.0 ft.

W from E line house 2.0 ft.

Feb. 2, 1965 Renewed service from 6" outside curb stop to 3' inside curb stop  
 3 1/2' 3/4" copper tubing  
 3/4" cop. to cop. stop, fig. 415 2 lbs. wiping solder

8/24/89: Renewed from 1/2' outside curb stop to prop line  
 Stock: 9 ft. 3/4" copper tubing 1-3/4" curb stop  
 1 - Caldwell stop box 2-3/4x5/8 lead to cop adapt. xs.

6--4-1999 Renewed from main to a point 1 ft. Stock:  
 1 ft. 3/4" Copper tubing, 1 - 5/8"x3/4" lead to cop. adapt. XXS, 1 - 5/8"x3/4" Fig. 413.

POOR PRESSURE 6/2/99

8-10-2000 Renewed from foundation to a point 8 ft. outside foundation. Stock: 8 ft. - 3/4" Copper tubing  
 2 - 5/8" x 3/4" lead to cop. adapt.XS.

8/20/00 Renewed from 3 ft. inside curb stop to a point 8 ft. ins. property line.  
 13 ft. - 3/4" copper tubing; 5/8" x 3/4" lead to cop adapt XS; 3/4" x 3/4" cop to cop cplg.  
 Note: Ripped out by Waste Water.

- OVER -



[illegible]

## CHARGE OUTS'

[illegible]