

APPLICATION No.: 1474

TAP CLEARED

LOCATION: 55 Hill

OWNER: Thos. F. Girriocer

MEASURES:

N from	North	101.4 ft.
E from W line	Hill	6.7 ft.
S from S line	house	3.6 ft.

7/12/79: Franklin renewed service from the main to the prop. line. 18 ft. - 3/4" copper; 3/4" curb stop; stop box; 5/8" x 3/4" ~~Fig. 413~~; 3/4" corp. tap

LEAD - COP ADAPT x 5

8/16/80 Dug stop box - shut off - leak going into house hooked up house to house connections.  
Sidewalk cut: 3' x 3' Cement

8/20/80 Service was not completely renewed to the property line - Franklin had to go back and renew from 3 ft. outside property line to inside bldg.  
There is a 3/4" x 3/4" cop to cop cplg. at a point 3 ft. outside property line.  
All work done by Franklin Const. & Owners plumber.  
Turned by Camara

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

DIAG	SAFE	199	2806383
------	------	-----	---------

7/9

7/9/99

SENT A CREW TO CHECK  
FOR A LEAK AT THIS  
ADDRESS. COULD NOT FIND  
ANY PROBLEMS.



[illegible]

## This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, characteristic of old paper. The left edge of the page shows the binding structure, including the stitching and the inner cover material. There is no text or other markings on the page.